



## **Empty boxes**




## FP 0420


- Built-in dimensions W 486 x H 306 x D 140 mm
- door fastener with tool operation
- max. installation depth with built-in mounting plate 136 mm, with built-in DIN rail 125 mm
- with opaque door
- box size 4
- · sealing device for door sealing order separately
- please order DIN rails, mounting plates or covers additionally
- connector: 6 items
- in orer to achieve protection class II and degree of protection IP 65, please order closing plate sets, single closing plates and flanges separately
- material: PC (polycarbonate)
- protection class: II
- colour: grey, RAL 7035

width	540 mm
height	360 mm
depth	163 mm
weight	3,618 kg


## Drawings



**Dimension drawing** 







## **Operating and ambient conditions**

1 5	
Application area	Suitable for indoor installation and outdoor installation, protected against weather influences However, pay attention to the climatic effects on the installed equipment , for example, high or low ambient temperatures or formation of condensed water see technical information
Ambient temperature	Maximum value + 70 °C Minimum value - 25 °C
Fire protection in the event of internal faults	Demands placed on electrical devices from standards and laws Minimum requirements - Glow wire test in accordance with IEC 60695-2-11: - 650°C for boxes and cable glands - 850°C for parts of insulating material necessary to retain current carrying parts in position
Burning behaviour	Glow wire test IEC 60695-2-11: 960 °C UL Subject 94: V-2 flame-retardant self-extinguishing

Gustav Hensel GmbH & Co. KG \* Gustav-Hensel-Str. 6 \* 57368 Lennestadt \* Germany \* Telefon: +49 (0)2723/609-0 \* Fax: +49 (0)2723/60052 \* Date: December 13. 2023

Degree of protection against mechanical load	IK08 (5 Joule)
Toxic behaviour	halogen-free silicone-free "halogen-free" in accordance with the examination of the cables and insulated wires - corrosiveness of fumes - as per IEC 60754-2
Note:	Additional information for protected outdoor installation: - In order to keep the maximum permissible ambient temperature of the installed equipment as well for the prevention from condensation additional measures as ventilation and/or heating may be necessary. For material properties see technical data.